



**NOTES:**

1. THE FINISHED FLOOR IN THE IDF SHALL BE STATIC DISSIPATIVE. FLOOR STATIC STRIP SHALL BE PROVIDED AT SURFACE DIRECTLY BELOW GROUND BUS BAR.
2. FOR SCHOOL ADDITIONS, PROVIDE (2) 25-PAIR CAT 5E CABLES TO EXISTING MDF.
3. VERIFY EXACT IDF LAYOUT WITH CPS ITS SR. INFRASTRUCTURE MANAGER (773-553-6030).
4. PROVIDE (5) 2 INCH CONDUITS.
  - a. (1)-2 INCH FOR (4) 25-PAIR CAT 5E FROM MDF.
  - b. (1)-2 INCH FOR FIBER FROM MDF.
    - i. (1)-6 STRAND FOR SECURITY
    - ii. (2)-6 STRAND FOR DATA
  - c. (1)-2 INCH FOR COAX - RG-59 FROM MDF.
  - d. (1)-2 INCH SPARE FROM MDF.
  - e. (1)-2 INCH FOR INTERCOM CONNECTIVITY FROM EXISTING HEADEND. IT IS THE CONTRACTOR'S RESPONSIBILITY TO CONFIRM EXACT CONDUIT SIZE WITH INTERCOM SYSTEM MANUFACTURER.

<b>CHICAGO PUBLIC SCHOOLS CAPITAL IMPROVEMENT PROGRAM INFORMATION TECHNOLOGY SERVICES INFRASTRUCTURE STANDARDS</b>																							
<b>TYPICAL IDF ROOM PLAN</b>																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">DESIGNED</td> <td style="width: 30%;">CPS</td> <td rowspan="4" style="width: 20%;"></td> <td rowspan="4" style="width: 30%;"></td> </tr> <tr> <td>DRAWN</td> <td>CPS</td> </tr> <tr> <td>CHECKED</td> <td>CPS</td> </tr> <tr> <td>APPROVED</td> <td>CPS</td> </tr> <tr> <td>NO.</td> <td>DATE</td> <td>REVISION</td> <td>BY</td> </tr> </table>	DESIGNED	CPS			DRAWN	CPS	CHECKED	CPS	APPROVED	CPS	NO.	DATE	REVISION	BY	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align: center;">PROJECT NUMBER</td> <td style="text-align: center;">SCALE</td> <td style="text-align: center;">DATE</td> </tr> <tr> <td colspan="2" style="text-align: center;">NONE</td> <td style="text-align: center;">04/23/18</td> <td style="text-align: center;">ED.131</td> </tr> </table>	PROJECT NUMBER		SCALE	DATE	NONE		04/23/18	ED.131
DESIGNED	CPS																						
DRAWN	CPS																						
CHECKED	CPS																						
APPROVED	CPS																						
NO.	DATE	REVISION	BY																				
PROJECT NUMBER		SCALE	DATE																				
NONE		04/23/18	ED.131																				