



- NOTES:
1. PROVIDE A 36"W x 36"L x 12"D NEMA 3R RATED ENCLOSURE WITH LOCKING DOOR.
 2. THE ENCLOSURE'S DOOR SHALL BE MONITORED BY DOOR POSITION SWITCH CONNECTED TO THE EXISTING HONEYWELL VISTA 50P INTRUSION DETECTION SYSTEM.
 3. EACH COMPONENT SHALL BE MOUNTED WITH A MINIMUM OF 2" OF SPACE BETWEEN ADJACENT COMPONENTS OR THE ENCLOSURE WALL.
 4. REFER TO SITE PLAN AND DETAILS FOR CABLE REQUIREMENTS AND ROUTING.
 5. PROVIDE A 6AWG GROUNDING CABLE CONNECTION FROM IT ENCLOSURE TGB BACK TO NEAREST ELECTRICAL GROUNDING SYSTEM.

CHICAGO PUBLIC SCHOOLS
 CAPITAL IMPROVEMENT PROGRAM
 OFFICE OF SAFETY AND SECURITY
 SECURITY STANDARDS
 IT ENCLOSURE "NE-2"DETAIL



DESIGNED	CPS			
DRAWN	CPS			
CHECKED	CPS			
APPROVED	CPS			
NO.	DATE	REVISION	BY	

PROJECT:	ITS SYSTEM-DETAILS		
PROJECT NUMBER	SCALE	DATE	
XXXX	NONE	02/27/19	

SHEET NO.	ED-241
-----------	--------